



The FAIR pLINAC RF Systems


Libera Workshop
Sep. 2011

Gerald Schreiber

- (1) Overview GSI / FAIR
- (2) FAIR Proton Linear Accelerator "pLinac"
- (3) pLinac RF Systems
- (4) First experience with the Libera LLRF
- (5) pLinac Klystron- and Cavity Test Stand at GSI
- (6) Conclusion

GSI - Helmholtzzentrum für Schwerionenforschung mbH
Heavy Ion Accelerator Facility





UNILAC

a 120 meter long linear accelerator,
2 – 11.4 MeV/u

SIS 18

217m circumference,
up to 2 GeV/u

ESR

accelerated ions, whether stable or radioactive can be stored up to several hours

Phelix / Nhelix

High energy lasers

GSI general

| | |
|-------------------------------|--|
| Foundation | 1969 |
| Associates | Federal Republic of Germany (90%), State of Hessen (10%) |
| Member | Helmholtz Association |
| Task | Construction and operation of accelerator facilities and research of heavy accelerated ions in the range from He to U. |
| Staff | ~1100 employees, including 600 scientists and engineers |
| Capital equipment | Linear accelerator UNILAC Heavy ion synchrotron SIS Experiment storage ring ESR Fragment separator FRS High-energy/high-efficiency laser PHELIX (being constructed) Several large systems of spectrometers and detectors Medical irradiation unit for cancer therapy |
| Scientific Cooperation | Users of the GSI facilities are predominantly non-resident scientists, mainly from German Universities (totalling over 1,000 scientists per year). World-wide cooperation with approximately 400 institutes from over 50 countries. |


FAIR – Facility for Antiproton- and Ion Research



8th of Nov. 2007: Official
Project Start

16 FAIR Partner countries

More than 40 countries
involved






currently planned Libera applications at GSI and FAIR:

| | |
|---------|--|
| pLinac: | 10 x LLRF xx Pickups(for BPM and TOF) 118 MSa/s "undersampling" |
| SIS18: | 12 BPMs |
| SIS100: | 84 BPMs |
| CR: | 18 BPMs |
| HEBT: | 40 BPMs |
| ... | ... |

Linac on first floor - "Klystron Gallery" on second floor


Klystron HV Power Supplies, 1st fl.




1st floor

RF Cavities, 1st fl.

Klystron Gallery, 2nd fl.





2nd floor




- ECR proton source & LEBT
 - RFQ
 - Klystron
 - 3 re-bunchers
 - Solid State Amplifiers, 45 kW
 - 6 accelerating cavities
 - 6 Klystrons (2.5 MW)
 - 2 dipoles, 45 quadrupoles, 7 steerers
 - 10 turbo pumps, 34 ion pumps, 9 sector valves
 - 41 beam diagnostic devices
- 10 RF Systems

| | |
|----------------------------|---------------------|
| Beam energy | 70 MeV |
| Beam current (op.) | 35 mA |
| <u>Beam current (des.)</u> | <u>70 mA</u> |
| Beam pulse length | 36 µs |
| Repetition rate | 5 Hz |
| RF-frequency | 325.224 MHz |
| Tot. hor emit (norm.) | 2.1 / <u>4.2</u> µm |
| Tot. mom. spread | $\leq \pm 10^{-3}$ |
| Linac length | ≈ 35 m |







Measurement + Fast Interlock rack for

- data acquisition by sample&hold during the RF pulse
- fast interlock generation by adjustable thresholds
- output of sampled values for the PLC and analog instruments
- monitoring of RF signals by oscilloscope and fast sampling cards

PLC (SIEMENS S7-400) for

- visualization of sampled values (power, ps voltages etc.)
- visualization of slow signals (cooling water flow, temperatures etc.)
- controlling the power up/down sequence of all components
- slow interlock handling
- status reporting to the FAIR central control system




pLinac RF Systems: Requirements for the LLRF



- 325.224 MHz
- Up to 5 Hz, 70 to 200 us RF pulse length (safety margin incl.)
- Heavy beamload expected, (1.2 -> 2.5 MW)
- Triggers for external devices (Klystron Power Supplies, Fast Interlock Rack, etc...)
- Fast interlock inputs (arc detection system, klystron safety, personal safety...)
- Local operation mode, local GUI for “RF experts”
- Accuracy: 0.1% in amplitude and 0.5° in phase (max!)
- Control system integration, Timing

Timing Interface
GSI and CERN
development,
deterministic Ethernet-
based field bus :

White Rabbit



LLRF Tests at GSI (Linac-HF):


Old RF test cavity tuned on 325.224 MHz (fixed)

325.224 MHz reference oscillator

Libera LLRF controller


100 W power amplifier

RF Mixer for beam loading simulation




Laboratory conditions for the first tests with the Libera LLRF:





- Rectangular RF pulse (set value), no "preshaping"
- Only rough optimization of PI control parameters
- Reference oscillator phase noise: < -105dB/Hz (df=20kHz) ☹
- Beam loading "by mixer" not optimal
- no feed-forward implemented yet



RF output ON Libera system. 192.160.1.1 (1.2-9999-r9999 devbuild) Loop closed 1.2-114-r7922 trb-rc1

GUI by Instrumentation Technologies






Ampl. drop:~ 20%

Ampl. 0.18 %
Phase 0.12 °

Planned RF test bench for the klystrons and the pLinac cavities:

- Klystron already available (Toshiba E3740GSI)
- Power supplies by Transtechnik (ready March 2012)
- Low-level-RF ordered (feed forward and feedback): Instrumentation Technologies
- Circulator, RF load and waveguides from commercial manufacturers
- Driver amplifier from "RES Ingenium / Italy" (already delivered and tested)
- Delivery of first CH cavity: Dec. 2011
- RF operation at test stand: June 2012



- The FAIR pLinac plannings are in progress, building construction starts in 2012, pLinac ready for commissioning: 2017
- A dedicated RF test stand is under construction for klystron- and cavity tests, first RF tests mid of 2012
- pLinac LLRF control loops: slovenian inkind contribution
- first experience with the Libera LLRF test system
 - Even with further optimizations (PI parameters, experimental setup, ...) an LLRF feed-forward implementation for the beam loading compensation is recommended!
 - Pulse pre-shaping is needed
 - Linearization of klystron gain (?)